

AOV ROOF VENT
CLEAR FREE AREA OF 1.0m² REQUIRED



TOP LEVEL CALL POINT
ADJACENT TO AOV'S



SMOKE DETECTOR AT
TOP OF STAIRWELL



A



B



SMOKE DETECTOR AT
G¹⁰ FL STAIRWELL




A



B



ENTRANCE LEVEL CALL POINT
FOR FIRE SERVICE USE



SVM SMOKE CONTROL PANEL C/W 72HR
BATTERY BACKUP
EN12101-10 COMPLIANT
238x286x113mm (WxHxD)

CAN BE LOCATED IN RISER CUPBOARD ON
ANY LEVEL




230v 5A UN-SWITCHED FUSED SPUR AT
CONTROL PANEL LOCATION (BY OTHERS)

CABLE TYPES:

A: 2-CORE FP200 1.5MM

B: 6-CORES FP200 1.5MM (CAN BE MADE UP FROM 2-CORE + 4-CORE ETC)

Scale: NOT TO SCALE	Project: General Issue	 AOV & Fire Systems
Drawn: MK	Customer: General Issue	
Date: 5/2/16	Drawing Title: AOV Wiring, 2 Smokes, RH	DANE MILL BUSINESS CENTRE BROADHURST LANE CONGLETON CHESHIRE CW12 1LA
Revision: A – FIRST ISSUE	© FireBright Solutions Ltd 2016	